

HYDRO PRESSURE TEST

TC No.: HPT/MOD5/CA/RQ/026/25	Model No.: KMCRQ-5	Date: 18-04-2025
Type and Capacity of Extinguisher	: KMCRQ-5-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 5 Kg.	
Batch Number	: KMCRQ5 026/25	
Batch Quantity	: 50.00 Nos.	
Serial Numbers	: 01251 To 1300	
Month of Manufacturing	: Apr/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 01251 To 1300 and removed from the Lot/Batch							
1251	Pass	1252	Pass	1253	Pass	1254	Pass
1255	Pass	1256	Pass	1257	Pass	1258	Pass
1259	Pass	1260	Pass	1261	Pass	1262	Pass
1263	Pass	1264	Pass	1265	Pass	1266	Pass
1267	Pass	1268	Pass	1269	Pass	1270	Pass
1271	Pass	1272	Pass	1273	Pass	1274	Pass
1275	Pass	1276	Pass	1277	Pass	1278	Pass
1279	Pass	1280	Pass	1281	Pass	1282	Pass
1283	Pass	1284	Pass	1285	Pass	1286	Pass
1287	Pass	1288	Pass	1289	Pass	1290	Pass
1291	Pass	1292	Pass	1293	Pass	1294	Pass
1295	Pass	1296	Pass	1297	Pass	1298	Pass
1299	Pass	1300	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory