

HYDRO PRESSURE TEST

TC No.: HPT/MA4/A40/RQ/001/26	Model No.: MARQ-4-40%	Date: 03-01-2026
Type and Capacity of Extinguisher	: MARQ-4-40%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg.	
Batch Number	: MARQ40%4 001/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 00001 To 100 And 5A	
Month of Manufacturing	: Jan/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on d 5A and removed from the Lot/Batch							
1	Pass	2	Pass	3	Pass	4	Pass
5	Pass	6	Pass	7	Pass	8	Pass
9	Pass	10	Pass	11	Pass	12	Pass
13	Pass	14	Pass	15	Pass	16	Pass
17	Pass	18	Pass	19	Pass	20	Pass
21	Pass	22	Pass	23	Pass	24	Pass
25	Pass	26	Pass	27	Pass	28	Pass
29	Pass	30	Pass	31	Pass	32	Pass
33	Pass	34	Pass	35	Pass	36	Pass
37	Pass	38	Pass	39	Pass	40	Pass
41	Pass	42	Pass	43	Pass	44	Pass
45	Pass	46	Pass	47	Pass	48	Pass
49	Pass	50	Pass	51	Pass	52	Pass
53	Pass	54	Pass	55	Pass	56	Pass
57	Pass	58	Pass	59	Pass	60	Pass
61	Pass	62	Pass	63	Pass	64	Pass
65	Pass	66	Pass	67	Pass	68	Pass
69	Pass	70	Pass	71	Pass	72	Pass
73	Pass	74	Pass	75	Pass	76	Pass
77	Pass	78	Pass	79	Pass	80	Pass
81	Pass	82	Pass	83	Pass	84	Pass
85	Pass	86	Pass	87	Pass	88	Pass
89	Pass	90	Pass	91	Pass	92	Pass
93	Pass	94	Pass	95	Pass	96	Pass
97	Pass	98	Pass	99	Pass	100	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory