

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/031/26	Model No.: MARQ-6-40%	Date: 01-02-2026
Type and Capacity of Extinguisher	: MARQ-6-40%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ40%6 031/26	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 03001 To 3100 And 3005A	
Month of Manufacturing	: Feb/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 3005A and removed from the Lot/Batch							
3001	Pass	3002	Pass	3003	Pass	3004	Pass
3005	Pass	3006	Pass	3007	Pass	3008	Pass
3009	Pass	3010	Pass	3011	Pass	3012	Pass
3013	Pass	3014	Pass	3015	Pass	3016	Pass
3017	Pass	3018	Pass	3019	Pass	3020	Pass
3021	Pass	3022	Pass	3023	Pass	3024	Pass
3025	Pass	3026	Pass	3027	Pass	3028	Pass
3029	Pass	3030	Pass	3031	Pass	3032	Pass
3033	Pass	3034	Pass	3035	Pass	3036	Pass
3037	Pass	3038	Pass	3039	Pass	3040	Pass
3041	Pass	3042	Pass	3043	Pass	3044	Pass
3045	Pass	3046	Pass	3047	Pass	3048	Pass
3049	Pass	3050	Pass	3051	Pass	3052	Pass
3053	Pass	3054	Pass	3055	Pass	3056	Pass
3057	Pass	3058	Pass	3059	Pass	3060	Pass
3061	Pass	3062	Pass	3063	Pass	3064	Pass
3065	Pass	3066	Pass	3067	Pass	3068	Pass
3069	Pass	3070	Pass	3071	Pass	3072	Pass
3073	Pass	3074	Pass	3075	Pass	3076	Pass
3077	Pass	3078	Pass	3079	Pass	3080	Pass
3081	Pass	3082	Pass	3083	Pass	3084	Pass
3085	Pass	3086	Pass	3087	Pass	3088	Pass
3089	Pass	3090	Pass	3091	Pass	3092	Pass
3093	Pass	3094	Pass	3095	Pass	3096	Pass
3097	Pass	3098	Pass	3099	Pass	3100	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory