

HYDRO PRESSURE TEST

TC No.: HPT/MOD10/CA/RQ/166/25	Model No.: KMCRQ-10	Date: 08-11-2025
Type and Capacity of Extinguisher	: KMCRQ-10-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 10 Kg.	
Batch Number	: KMCRQ10 166/25	
Batch Quantity	: 10.00 Nos.	
Serial Numbers	: 01651 To 1660	
Month of Manufacturing	: Nov/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 01651 To 1660 and removed from the Lot/Batch							
1651	Pass	1652	Pass	1653	Pass	1654	Pass
1655	Pass	1656	Pass	1657	Pass	1658	Pass
1659	Pass	1660	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory