

# HYDRO PRESSURE TEST

|                                   |                                                              |                  |
|-----------------------------------|--------------------------------------------------------------|------------------|
| TC No.: HPT/A6/MDS/RQ/013/25      | Model No.: MDSRQ-6                                           | Date: 22-06-2025 |
| Type and Capacity of Extinguisher | : MDSRQ-6-Kanex BC Dry Powder SP Fire Extinguisher Cap. 6 Kg |                  |
| Batch Number                      | : MDSRQ6 013/25                                              |                  |
| Batch Quantity                    | : 51.00 Nos.                                                 |                  |
| Serial Numbers                    | : 00601 To 650 And 605A                                      |                  |
| Month of Manufacturing            | : Jun/25                                                     |                  |

| Sr. Nos.                                                    | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|-------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 605A and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 601                                                         | Pass   | 602      | Pass   | 603      | Pass   | 604      | Pass   |
| 605                                                         | Pass   | 606      | Pass   | 607      | Pass   | 608      | Pass   |
| 609                                                         | Pass   | 610      | Pass   | 611      | Pass   | 612      | Pass   |
| 613                                                         | Pass   | 614      | Pass   | 615      | Pass   | 616      | Pass   |
| 617                                                         | Pass   | 618      | Pass   | 619      | Pass   | 620      | Pass   |
| 621                                                         | Pass   | 622      | Pass   | 623      | Pass   | 624      | Pass   |
| 625                                                         | Pass   | 626      | Pass   | 627      | Pass   | 628      | Pass   |
| 629                                                         | Pass   | 630      | Pass   | 631      | Pass   | 632      | Pass   |
| 633                                                         | Pass   | 634      | Pass   | 635      | Pass   | 636      | Pass   |
| 637                                                         | Pass   | 638      | Pass   | 639      | Pass   | 640      | Pass   |
| 641                                                         | Pass   | 642      | Pass   | 643      | Pass   | 644      | Pass   |
| 645                                                         | Pass   | 646      | Pass   | 647      | Pass   | 648      | Pass   |
| 649                                                         | Pass   | 650      | Pass   |          |        |          |        |

**Remarks:** This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



**Authorized Signatory**