

HYDRO PRESSURE TEST

TC No.: HPT/A9/K/HQ/030/25	Model No.: KFKHQ-9	Date: 01-07-2025
Type and Capacity of Extinguisher	: KFKHQ-9-Kanex F Class Kitchen Fire Extinguisher Cap. 9 Ltr.	
Batch Number	: KFKHQ9 030/25	
Batch Quantity	: 10.00 Nos.	
Serial Numbers	: 00291 To 300	
Month of Manufacturing	: Jul/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 00291 To 300 and removed from the Lot/Batch							
291	Pass	292	Pass	293	Pass	294	Pass
295	Pass	296	Pass	297	Pass	298	Pass
299	Pass	300	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory