

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/150/25	Model No.: MARQ-6-40%	Date: 19-08-2025
Type and Capacity of Extinguisher	: MARQ-6-40%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ40%6 150/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 14901 To 15000 And 14905A	
Month of Manufacturing	: Aug/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 14905A and removed from the Lot/Batch							
14901	Pass	14902	Pass	14903	Pass	14904	Pass
14905	Pass	14906	Pass	14907	Pass	14908	Pass
14909	Pass	14910	Pass	14911	Pass	14912	Pass
14913	Pass	14914	Pass	14915	Pass	14916	Pass
14917	Pass	14918	Pass	14919	Pass	14920	Pass
14921	Pass	14922	Pass	14923	Pass	14924	Pass
14925	Pass	14926	Pass	14927	Pass	14928	Pass
14929	Pass	14930	Pass	14931	Pass	14932	Pass
14933	Pass	14934	Pass	14935	Pass	14936	Pass
14937	Pass	14938	Pass	14939	Pass	14940	Pass
14941	Pass	14942	Pass	14943	Pass	14944	Pass
14945	Pass	14946	Pass	14947	Pass	14948	Pass
14949	Pass	14950	Pass	14951	Pass	14952	Pass
14953	Pass	14954	Pass	14955	Pass	14956	Pass
14957	Pass	14958	Pass	14959	Pass	14960	Pass
14961	Pass	14962	Pass	14963	Pass	14964	Pass
14965	Pass	14966	Pass	14967	Pass	14968	Pass
14969	Pass	14970	Pass	14971	Pass	14972	Pass
14973	Pass	14974	Pass	14975	Pass	14976	Pass
14977	Pass	14978	Pass	14979	Pass	14980	Pass
14981	Pass	14982	Pass	14983	Pass	14984	Pass
14985	Pass	14986	Pass	14987	Pass	14988	Pass
14989	Pass	14990	Pass	14991	Pass	14992	Pass
14993	Pass	14994	Pass	14995	Pass	14996	Pass
14997	Pass	14998	Pass	14999	Pass	15000	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory