

HYDRO PRESSURE TEST

TC No.: HPT/A6/A90/RQ/223/25	Model No.: KFARQ-6-90%	Date: 04-08-2025
Type and Capacity of Extinguisher	: KFARQ-6-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ90%6 223/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 22201 To 22300 And 22205A	
Month of Manufacturing	: Aug/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 22205A and removed from the Lot/Batch							
22201	Pass	22202	Pass	22203	Pass	22204	Pass
22205	Pass	22206	Pass	22207	Pass	22208	Pass
22209	Pass	22210	Pass	22211	Pass	22212	Pass
22213	Pass	22214	Pass	22215	Pass	22216	Pass
22217	Pass	22218	Pass	22219	Pass	22220	Pass
22221	Pass	22222	Pass	22223	Pass	22224	Pass
22225	Pass	22226	Pass	22227	Pass	22228	Pass
22229	Pass	22230	Pass	22231	Pass	22232	Pass
22233	Pass	22234	Pass	22235	Pass	22236	Pass
22237	Pass	22238	Pass	22239	Pass	22240	Pass
22241	Pass	22242	Pass	22243	Pass	22244	Pass
22245	Pass	22246	Pass	22247	Pass	22248	Pass
22249	Pass	22250	Pass	22251	Pass	22252	Pass
22253	Pass	22254	Pass	22255	Pass	22256	Pass
22257	Pass	22258	Pass	22259	Pass	22260	Pass
22261	Pass	22262	Pass	22263	Pass	22264	Pass
22265	Pass	22266	Pass	22267	Pass	22268	Pass
22269	Pass	22270	Pass	22271	Pass	22272	Pass
22273	Pass	22274	Pass	22275	Pass	22276	Pass
22277	Pass	22278	Pass	22279	Pass	22280	Pass
22281	Pass	22282	Pass	22283	Pass	22284	Pass
22285	Pass	22286	Pass	22287	Pass	22288	Pass
22289	Pass	22290	Pass	22291	Pass	22292	Pass
22293	Pass	22294	Pass	22295	Pass	22296	Pass
22297	Pass	22298	Pass	22299	Pass	22300	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory