

HYDRO PRESSURE TEST

TC No.: HPT/A6/A90/RQ/228/25	Model No.: KFARQ-6-90%	Date: 19-08-2025
Type and Capacity of Extinguisher	: KFARQ-6-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ90%6 228/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 22701 To 22800 And 22705A	
Month of Manufacturing	: Aug/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 22705A and removed from the Lot/Batch							
22701	Pass	22702	Pass	22703	Pass	22704	Pass
22705	Pass	22706	Pass	22707	Pass	22708	Pass
22709	Pass	22710	Pass	22711	Pass	22712	Pass
22713	Pass	22714	Pass	22715	Pass	22716	Pass
22717	Pass	22718	Pass	22719	Pass	22720	Pass
22721	Pass	22722	Pass	22723	Pass	22724	Pass
22725	Pass	22726	Pass	22727	Pass	22728	Pass
22729	Pass	22730	Pass	22731	Pass	22732	Pass
22733	Pass	22734	Pass	22735	Pass	22736	Pass
22737	Pass	22738	Pass	22739	Pass	22740	Pass
22741	Pass	22742	Pass	22743	Pass	22744	Pass
22745	Pass	22746	Pass	22747	Pass	22748	Pass
22749	Pass	22750	Pass	22751	Pass	22752	Pass
22753	Pass	22754	Pass	22755	Pass	22756	Pass
22757	Pass	22758	Pass	22759	Pass	22760	Pass
22761	Pass	22762	Pass	22763	Pass	22764	Pass
22765	Pass	22766	Pass	22767	Pass	22768	Pass
22769	Pass	22770	Pass	22771	Pass	22772	Pass
22773	Pass	22774	Pass	22775	Pass	22776	Pass
22777	Pass	22778	Pass	22779	Pass	22780	Pass
22781	Pass	22782	Pass	22783	Pass	22784	Pass
22785	Pass	22786	Pass	22787	Pass	22788	Pass
22789	Pass	22790	Pass	22791	Pass	22792	Pass
22793	Pass	22794	Pass	22795	Pass	22796	Pass
22797	Pass	22798	Pass	22799	Pass	22800	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory