

HYDRO PRESSURE TEST

TC No.: HPT/MOD5/CA/RQ/058/25	Model No.: KMCRQ-5	Date: 27-08-2025
Type and Capacity of Extinguisher	: KMCRQ-5-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 5 Kg.	
Batch Number	: KMCRQ5 058/25	
Batch Quantity	: 50.00 Nos.	
Serial Numbers	: 02851 To 2900	
Month of Manufacturing	: Aug/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 02851 To 2900 and removed from the Lot/Batch							
2851	Pass	2852	Pass	2853	Pass	2854	Pass
2855	Pass	2856	Pass	2857	Pass	2858	Pass
2859	Pass	2860	Pass	2861	Pass	2862	Pass
2863	Pass	2864	Pass	2865	Pass	2866	Pass
2867	Pass	2868	Pass	2869	Pass	2870	Pass
2871	Pass	2872	Pass	2873	Pass	2874	Pass
2875	Pass	2876	Pass	2877	Pass	2878	Pass
2879	Pass	2880	Pass	2881	Pass	2882	Pass
2883	Pass	2884	Pass	2885	Pass	2886	Pass
2887	Pass	2888	Pass	2889	Pass	2890	Pass
2891	Pass	2892	Pass	2893	Pass	2894	Pass
2895	Pass	2896	Pass	2897	Pass	2898	Pass
2899	Pass	2900	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory