

## HELIUM LEAK DETECTION TEST

|                                   |                                                                      |                  |
|-----------------------------------|----------------------------------------------------------------------|------------------|
| TC No.: HLD/A4/A50/SS/HQ/014/25   | Model No.: KFASSHQ-4-50%                                             | Date: 18-08-2025 |
| Type and Capacity of Extinguisher | : KFASSHQ-4-50%-Kanex ABC Dry Powder SS Fire Extinguisher Cap. 4 Kg. |                  |
| Batch Number                      | : KFASSHQ50%4 014/25                                                 |                  |
| Batch Quantity                    | : 10 Nos.                                                            |                  |
| Serial Numbers                    | : 00131 To 140                                                       |                  |
| Month of Manufacturing            | : Aug/25                                                             |                  |

| Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|----------|--------|----------|--------|----------|--------|----------|--------|
| 131      | Pass   | 132      | Pass   | 133      | Pass   | 134      | Pass   |
| 135      | Pass   | 136      | Pass   | 137      | Pass   | 138      | Pass   |
| 139      | Pass   | 140      | Pass   |          |        |          |        |

**Remarks:** This is to certify that the above mentioned Fire Extinguishers has been tested on Mass Spectrometer Helium Leak Detector, with test pressure of 1 mbar and desired leak rate of  $1 \times 10^{-6}$  mbar.l/sec and no any cylinders shows leakage beyond this limit.



**Authorized Signatory**