

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/146/25	Model No.: MARQ-6-40%	Date: 19-08-2025
Type and Capacity of Extinguisher	: MARQ-6-40%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ40%6 146/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 14501 To 14600 And 14505A	
Month of Manufacturing	: Aug/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 14505A and removed from the Lot/Batch							
14501	Pass	14502	Pass	14503	Pass	14504	Pass
14505	Pass	14506	Pass	14507	Pass	14508	Pass
14509	Pass	14510	Pass	14511	Pass	14512	Pass
14513	Pass	14514	Pass	14515	Pass	14516	Pass
14517	Pass	14518	Pass	14519	Pass	14520	Pass
14521	Pass	14522	Pass	14523	Pass	14524	Pass
14525	Pass	14526	Pass	14527	Pass	14528	Pass
14529	Pass	14530	Pass	14531	Pass	14532	Pass
14533	Pass	14534	Pass	14535	Pass	14536	Pass
14537	Pass	14538	Pass	14539	Pass	14540	Pass
14541	Pass	14542	Pass	14543	Pass	14544	Pass
14545	Pass	14546	Pass	14547	Pass	14548	Pass
14549	Pass	14550	Pass	14551	Pass	14552	Pass
14553	Pass	14554	Pass	14555	Pass	14556	Pass
14557	Pass	14558	Pass	14559	Pass	14560	Pass
14561	Pass	14562	Pass	14563	Pass	14564	Pass
14565	Pass	14566	Pass	14567	Pass	14568	Pass
14569	Pass	14570	Pass	14571	Pass	14572	Pass
14573	Pass	14574	Pass	14575	Pass	14576	Pass
14577	Pass	14578	Pass	14579	Pass	14580	Pass
14581	Pass	14582	Pass	14583	Pass	14584	Pass
14585	Pass	14586	Pass	14587	Pass	14588	Pass
14589	Pass	14590	Pass	14591	Pass	14592	Pass
14593	Pass	14594	Pass	14595	Pass	14596	Pass
14597	Pass	14598	Pass	14599	Pass	14600	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory