

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/148/25	Model No.: MARQ-6-40%	Date: 19-08-2025
Type and Capacity of Extinguisher	: MARQ-6-40%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ40%6 148/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 14701 To 14800 And 14705A	
Month of Manufacturing	: Aug/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 14705A and removed from the Lot/Batch							
14701	Pass	14702	Pass	14703	Pass	14704	Pass
14705	Pass	14706	Pass	14707	Pass	14708	Pass
14709	Pass	14710	Pass	14711	Pass	14712	Pass
14713	Pass	14714	Pass	14715	Pass	14716	Pass
14717	Pass	14718	Pass	14719	Pass	14720	Pass
14721	Pass	14722	Pass	14723	Pass	14724	Pass
14725	Pass	14726	Pass	14727	Pass	14728	Pass
14729	Pass	14730	Pass	14731	Pass	14732	Pass
14733	Pass	14734	Pass	14735	Pass	14736	Pass
14737	Pass	14738	Pass	14739	Pass	14740	Pass
14741	Pass	14742	Pass	14743	Pass	14744	Pass
14745	Pass	14746	Pass	14747	Pass	14748	Pass
14749	Pass	14750	Pass	14751	Pass	14752	Pass
14753	Pass	14754	Pass	14755	Pass	14756	Pass
14757	Pass	14758	Pass	14759	Pass	14760	Pass
14761	Pass	14762	Pass	14763	Pass	14764	Pass
14765	Pass	14766	Pass	14767	Pass	14768	Pass
14769	Pass	14770	Pass	14771	Pass	14772	Pass
14773	Pass	14774	Pass	14775	Pass	14776	Pass
14777	Pass	14778	Pass	14779	Pass	14780	Pass
14781	Pass	14782	Pass	14783	Pass	14784	Pass
14785	Pass	14786	Pass	14787	Pass	14788	Pass
14789	Pass	14790	Pass	14791	Pass	14792	Pass
14793	Pass	14794	Pass	14795	Pass	14796	Pass
14797	Pass	14798	Pass	14799	Pass	14800	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory