

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/149/25	Model No.: MARQ-6-40%	Date: 19-08-2025
Type and Capacity of Extinguisher	: MARQ-6-40%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ40%6 149/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 14801 To 14900 And 14805A	
Month of Manufacturing	: Aug/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 14805A and removed from the Lot/Batch							
14801	Pass	14802	Pass	14803	Pass	14804	Pass
14805	Pass	14806	Pass	14807	Pass	14808	Pass
14809	Pass	14810	Pass	14811	Pass	14812	Pass
14813	Pass	14814	Pass	14815	Pass	14816	Pass
14817	Pass	14818	Pass	14819	Pass	14820	Pass
14821	Pass	14822	Pass	14823	Pass	14824	Pass
14825	Pass	14826	Pass	14827	Pass	14828	Pass
14829	Pass	14830	Pass	14831	Pass	14832	Pass
14833	Pass	14834	Pass	14835	Pass	14836	Pass
14837	Pass	14838	Pass	14839	Pass	14840	Pass
14841	Pass	14842	Pass	14843	Pass	14844	Pass
14845	Pass	14846	Pass	14847	Pass	14848	Pass
14849	Pass	14850	Pass	14851	Pass	14852	Pass
14853	Pass	14854	Pass	14855	Pass	14856	Pass
14857	Pass	14858	Pass	14859	Pass	14860	Pass
14861	Pass	14862	Pass	14863	Pass	14864	Pass
14865	Pass	14866	Pass	14867	Pass	14868	Pass
14869	Pass	14870	Pass	14871	Pass	14872	Pass
14873	Pass	14874	Pass	14875	Pass	14876	Pass
14877	Pass	14878	Pass	14879	Pass	14880	Pass
14881	Pass	14882	Pass	14883	Pass	14884	Pass
14885	Pass	14886	Pass	14887	Pass	14888	Pass
14889	Pass	14890	Pass	14891	Pass	14892	Pass
14893	Pass	14894	Pass	14895	Pass	14896	Pass
14897	Pass	14898	Pass	14899	Pass	14900	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory