

HELIUM LEAK DETECTION TEST

TC No.: HLD/A6/K/HQ/074/25

Model No.: KFKHQ-6

Date: 10-09-2025

Type and Capacity of Extinguisher : KFKHQ-6-Kanex F Class Kitchen Fire Extinguisher Cap. 6 Ltr.

Batch Number : KFKHQ6 074/25

Batch Quantity : 10 Nos.

Serial Numbers : 00731 To 740

Month of Manufacturing : Sep/25

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
731	Pass	732	Pass	733	Pass	734	Pass
735	Pass	736	Pass	737	Pass	738	Pass
739	Pass	740	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers has been tested on Mass Spectrometer Helium Leak Detector, with test pressure of 1 mbar and desired leak rate of 1×10^{-6} mbar.l/sec and no any cylinders shows leakage beyond this limit.

**Authorized Signatory**