

# HYDRO PRESSURE TEST

|                                   |                                                               |                  |
|-----------------------------------|---------------------------------------------------------------|------------------|
| TC No.: HPT/A6/K/HQ/074/25        | Model No.: KFKHQ-6                                            | Date: 08-09-2025 |
| Type and Capacity of Extinguisher | : KFKHQ-6-Kanex F Class Kitchen Fire Extinguisher Cap. 6 Ltr. |                  |
| Batch Number                      | : KFKHQ6 074/25                                               |                  |
| Batch Quantity                    | : 11.00 Nos.                                                  |                  |
| Serial Numbers                    | : 00731 To 740 And 735A                                       |                  |
| Month of Manufacturing            | : Sep/25                                                      |                  |

| Sr. Nos.                                                    | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|-------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 735A and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 731                                                         | Pass   | 732      | Pass   | 733      | Pass   | 734      | Pass   |
| 735                                                         | Pass   | 736      | Pass   | 737      | Pass   | 738      | Pass   |
| 739                                                         | Pass   | 740      | Pass   |          |        |          |        |

**Remarks:** This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



**Authorized Signatory**