

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A90/RQ/021/25	Model No.: MARQ-6-90%	Date: 03-07-2025
Type and Capacity of Extinguisher	: MARQ-6-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ90%6 021/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 02001 To 2100 And 2005A	
Month of Manufacturing	: Jul/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 2005A and removed from the Lot/Batch							
2001	Pass	2002	Pass	2003	Pass	2004	Pass
2005	Pass	2006	Pass	2007	Pass	2008	Pass
2009	Pass	2010	Pass	2011	Pass	2012	Pass
2013	Pass	2014	Pass	2015	Pass	2016	Pass
2017	Pass	2018	Pass	2019	Pass	2020	Pass
2021	Pass	2022	Pass	2023	Pass	2024	Pass
2025	Pass	2026	Pass	2027	Pass	2028	Pass
2029	Pass	2030	Pass	2031	Pass	2032	Pass
2033	Pass	2034	Pass	2035	Pass	2036	Pass
2037	Pass	2038	Pass	2039	Pass	2040	Pass
2041	Pass	2042	Pass	2043	Pass	2044	Pass
2045	Pass	2046	Pass	2047	Pass	2048	Pass
2049	Pass	2050	Pass	2051	Pass	2052	Pass
2053	Pass	2054	Pass	2055	Pass	2056	Pass
2057	Pass	2058	Pass	2059	Pass	2060	Pass
2061	Pass	2062	Pass	2063	Pass	2064	Pass
2065	Pass	2066	Pass	2067	Pass	2068	Pass
2069	Pass	2070	Pass	2071	Pass	2072	Pass
2073	Pass	2074	Pass	2075	Pass	2076	Pass
2077	Pass	2078	Pass	2079	Pass	2080	Pass
2081	Pass	2082	Pass	2083	Pass	2084	Pass
2085	Pass	2086	Pass	2087	Pass	2088	Pass
2089	Pass	2090	Pass	2091	Pass	2092	Pass
2093	Pass	2094	Pass	2095	Pass	2096	Pass
2097	Pass	2098	Pass	2099	Pass	2100	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory