

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/263/25	Model No.: KFARQ-6-50%	Date: 18-08-2025
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 263/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 26201 To 26300 And 26205A	
Month of Manufacturing	: Aug/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 26205A and removed from the Lot/Batch							
26201	Pass	26202	Pass	26203	Pass	26204	Pass
26205	Pass	26206	Pass	26207	Pass	26208	Pass
26209	Pass	26210	Pass	26211	Pass	26212	Pass
26213	Pass	26214	Pass	26215	Pass	26216	Pass
26217	Pass	26218	Pass	26219	Pass	26220	Pass
26221	Pass	26222	Pass	26223	Pass	26224	Pass
26225	Pass	26226	Pass	26227	Pass	26228	Pass
26229	Pass	26230	Pass	26231	Pass	26232	Pass
26233	Pass	26234	Pass	26235	Pass	26236	Pass
26237	Pass	26238	Pass	26239	Pass	26240	Pass
26241	Pass	26242	Pass	26243	Pass	26244	Pass
26245	Pass	26246	Pass	26247	Pass	26248	Pass
26249	Pass	26250	Pass	26251	Pass	26252	Pass
26253	Pass	26254	Pass	26255	Pass	26256	Pass
26257	Pass	26258	Pass	26259	Pass	26260	Pass
26261	Pass	26262	Pass	26263	Pass	26264	Pass
26265	Pass	26266	Pass	26267	Pass	26268	Pass
26269	Pass	26270	Pass	26271	Pass	26272	Pass
26273	Pass	26274	Pass	26275	Pass	26276	Pass
26277	Pass	26278	Pass	26279	Pass	26280	Pass
26281	Pass	26282	Pass	26283	Pass	26284	Pass
26285	Pass	26286	Pass	26287	Pass	26288	Pass
26289	Pass	26290	Pass	26291	Pass	26292	Pass
26293	Pass	26294	Pass	26295	Pass	26296	Pass
26297	Pass	26298	Pass	26299	Pass	26300	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory