

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/144/25	Model No.: MARQ-6-40%	Date: 18-08-2025
Type and Capacity of Extinguisher	: MARQ-6-40%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ40%6 144/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 14301 To 14400 And 14305A	
Month of Manufacturing	: Aug/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 14305A and removed from the Lot/Batch							
14301	Pass	14302	Pass	14303	Pass	14304	Pass
14305	Pass	14306	Pass	14307	Pass	14308	Pass
14309	Pass	14310	Pass	14311	Pass	14312	Pass
14313	Pass	14314	Pass	14315	Pass	14316	Pass
14317	Pass	14318	Pass	14319	Pass	14320	Pass
14321	Pass	14322	Pass	14323	Pass	14324	Pass
14325	Pass	14326	Pass	14327	Pass	14328	Pass
14329	Pass	14330	Pass	14331	Pass	14332	Pass
14333	Pass	14334	Pass	14335	Pass	14336	Pass
14337	Pass	14338	Pass	14339	Pass	14340	Pass
14341	Pass	14342	Pass	14343	Pass	14344	Pass
14345	Pass	14346	Pass	14347	Pass	14348	Pass
14349	Pass	14350	Pass	14351	Pass	14352	Pass
14353	Pass	14354	Pass	14355	Pass	14356	Pass
14357	Pass	14358	Pass	14359	Pass	14360	Pass
14361	Pass	14362	Pass	14363	Pass	14364	Pass
14365	Pass	14366	Pass	14367	Pass	14368	Pass
14369	Pass	14370	Pass	14371	Pass	14372	Pass
14373	Pass	14374	Pass	14375	Pass	14376	Pass
14377	Pass	14378	Pass	14379	Pass	14380	Pass
14381	Pass	14382	Pass	14383	Pass	14384	Pass
14385	Pass	14386	Pass	14387	Pass	14388	Pass
14389	Pass	14390	Pass	14391	Pass	14392	Pass
14393	Pass	14394	Pass	14395	Pass	14396	Pass
14397	Pass	14398	Pass	14399	Pass	14400	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory