



Warranty Certificate

Date: 22-09-2025**Manufacturer:** Kanex Fire Solutions Limited.**Customer Name:** Venus Services**Warranty Start Date:** 22-09-2025**Warranty End Date:** 21-09-2026.

This is to certify that the below extinguishers are warranted for a period of **1** year from the date of supply against any of Manufacturing/Quality defects.

NOTE – IF TAMPER SEAL IS NOT INTACT, THE WARRANTY SHALL BE CONSIDERED VOID.

Sr.No.	Type & Capacity of Extinguishers	Quantity	Sr. Nos.
1	KFARQ-9-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 9 Kg. □□	41	As Per Annexure – I
2	KFCRQ-4.5-Kanex CO2 High Pressure Fire Extinguisher Cap. 4.5 Kg.	3	As Per Annexure – I
3	KFCRQ-9-Kanex CO2 High Pressure Fire Extinguisher Cap. 9 Kg.	4	As Per Annexure – I

Also certify that, all the Fire extinguishers supplied against Invoice No. **25-26/K/004061 Dated: 22-09-2025 P.O.No. MAIL 21-9-2025** are hydraulically tested 100% at 35 bar except CO2 and randomly tested for performance test. All the extinguishers confirms to IS 15683:2018 (Portable) or IS 16018:2012 (Mobile) requirements.

Note : If applicable CO2 Cylinders are PESO approved & HPT tested at 225 bar by Cylinder Manufacturer.

**Authorized Signatory**