

HYDRO PRESSURE TEST

TC No.: HPT/A4/A90/RQ/117/25	Model No.: KFARQ-4-90%	Date: 12-07-2025
Type and Capacity of Extinguisher	: KFARQ-4-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg.	
Batch Number	: KFARQ90%4 117/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 11601 To 11700 And 11605A	
Month of Manufacturing	: Jul/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 11605A and removed from the Lot/Batch							
11601	Pass	11602	Pass	11603	Pass	11604	Pass
11605	Pass	11606	Pass	11607	Pass	11608	Pass
11609	Pass	11610	Pass	11611	Pass	11612	Pass
11613	Pass	11614	Pass	11615	Pass	11616	Pass
11617	Pass	11618	Pass	11619	Pass	11620	Pass
11621	Pass	11622	Pass	11623	Pass	11624	Pass
11625	Pass	11626	Pass	11627	Pass	11628	Pass
11629	Pass	11630	Pass	11631	Pass	11632	Pass
11633	Pass	11634	Pass	11635	Pass	11636	Pass
11637	Pass	11638	Pass	11639	Pass	11640	Pass
11641	Pass	11642	Pass	11643	Pass	11644	Pass
11645	Pass	11646	Pass	11647	Pass	11648	Pass
11649	Pass	11650	Pass	11651	Pass	11652	Pass
11653	Pass	11654	Pass	11655	Pass	11656	Pass
11657	Pass	11658	Pass	11659	Pass	11660	Pass
11661	Pass	11662	Pass	11663	Pass	11664	Pass
11665	Pass	11666	Pass	11667	Pass	11668	Pass
11669	Pass	11670	Pass	11671	Pass	11672	Pass
11673	Pass	11674	Pass	11675	Pass	11676	Pass
11677	Pass	11678	Pass	11679	Pass	11680	Pass
11681	Pass	11682	Pass	11683	Pass	11684	Pass
11685	Pass	11686	Pass	11687	Pass	11688	Pass
11689	Pass	11690	Pass	11691	Pass	11692	Pass
11693	Pass	11694	Pass	11695	Pass	11696	Pass
11697	Pass	11698	Pass	11699	Pass	11700	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory