

HYDRO PRESSURE TEST

TC No.: HPT/A4/A90/RQ/122/25	Model No.: KFARQ-4-90%	Date: 20-07-2025
Type and Capacity of Extinguisher	: KFARQ-4-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg.	
Batch Number	: KFARQ90%4 122/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 12101 To 12200 And 12105A	
Month of Manufacturing	: Jul/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 12105A and removed from the Lot/Batch							
12101	Pass	12102	Pass	12103	Pass	12104	Pass
12105	Pass	12106	Pass	12107	Pass	12108	Pass
12109	Pass	12110	Pass	12111	Pass	12112	Pass
12113	Pass	12114	Pass	12115	Pass	12116	Pass
12117	Pass	12118	Pass	12119	Pass	12120	Pass
12121	Pass	12122	Pass	12123	Pass	12124	Pass
12125	Pass	12126	Pass	12127	Pass	12128	Pass
12129	Pass	12130	Pass	12131	Pass	12132	Pass
12133	Pass	12134	Pass	12135	Pass	12136	Pass
12137	Pass	12138	Pass	12139	Pass	12140	Pass
12141	Pass	12142	Pass	12143	Pass	12144	Pass
12145	Pass	12146	Pass	12147	Pass	12148	Pass
12149	Pass	12150	Pass	12151	Pass	12152	Pass
12153	Pass	12154	Pass	12155	Pass	12156	Pass
12157	Pass	12158	Pass	12159	Pass	12160	Pass
12161	Pass	12162	Pass	12163	Pass	12164	Pass
12165	Pass	12166	Pass	12167	Pass	12168	Pass
12169	Pass	12170	Pass	12171	Pass	12172	Pass
12173	Pass	12174	Pass	12175	Pass	12176	Pass
12177	Pass	12178	Pass	12179	Pass	12180	Pass
12181	Pass	12182	Pass	12183	Pass	12184	Pass
12185	Pass	12186	Pass	12187	Pass	12188	Pass
12189	Pass	12190	Pass	12191	Pass	12192	Pass
12193	Pass	12194	Pass	12195	Pass	12196	Pass
12197	Pass	12198	Pass	12199	Pass	12200	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory