

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/255/25	Model No.: MARQ-6-50%	Date: 03-08-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 255/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 25401 To 25500 And 25405A	
Month of Manufacturing	: Aug/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 25405A and removed from the Lot/Batch							
25401	Pass	25402	Pass	25403	Pass	25404	Pass
25405	Pass	25406	Pass	25407	Pass	25408	Pass
25409	Pass	25410	Pass	25411	Pass	25412	Pass
25413	Pass	25414	Pass	25415	Pass	25416	Pass
25417	Pass	25418	Pass	25419	Pass	25420	Pass
25421	Pass	25422	Pass	25423	Pass	25424	Pass
25425	Pass	25426	Pass	25427	Pass	25428	Pass
25429	Pass	25430	Pass	25431	Pass	25432	Pass
25433	Pass	25434	Pass	25435	Pass	25436	Pass
25437	Pass	25438	Pass	25439	Pass	25440	Pass
25441	Pass	25442	Pass	25443	Pass	25444	Pass
25445	Pass	25446	Pass	25447	Pass	25448	Pass
25449	Pass	25450	Pass	25451	Pass	25452	Pass
25453	Pass	25454	Pass	25455	Pass	25456	Pass
25457	Pass	25458	Pass	25459	Pass	25460	Pass
25461	Pass	25462	Pass	25463	Pass	25464	Pass
25465	Pass	25466	Pass	25467	Pass	25468	Pass
25469	Pass	25470	Pass	25471	Pass	25472	Pass
25473	Pass	25474	Pass	25475	Pass	25476	Pass
25477	Pass	25478	Pass	25479	Pass	25480	Pass
25481	Pass	25482	Pass	25483	Pass	25484	Pass
25485	Pass	25486	Pass	25487	Pass	25488	Pass
25489	Pass	25490	Pass	25491	Pass	25492	Pass
25493	Pass	25494	Pass	25495	Pass	25496	Pass
25497	Pass	25498	Pass	25499	Pass	25500	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory