

HYDRO PRESSURE TEST

TC No.: HPT/A4/A90/RQ/115/25	Model No.: KFARQ-4-90%	Date: 12-07-2025
Type and Capacity of Extinguisher	: KFARQ-4-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg.	
Batch Number	: KFARQ90%4 115/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 11401 To 11500 And 11405A	
Month of Manufacturing	: Jul/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 11405A and removed from the Lot/Batch							
11401	Pass	11402	Pass	11403	Pass	11404	Pass
11405	Pass	11406	Pass	11407	Pass	11408	Pass
11409	Pass	11410	Pass	11411	Pass	11412	Pass
11413	Pass	11414	Pass	11415	Pass	11416	Pass
11417	Pass	11418	Pass	11419	Pass	11420	Pass
11421	Pass	11422	Pass	11423	Pass	11424	Pass
11425	Pass	11426	Pass	11427	Pass	11428	Pass
11429	Pass	11430	Pass	11431	Pass	11432	Pass
11433	Pass	11434	Pass	11435	Pass	11436	Pass
11437	Pass	11438	Pass	11439	Pass	11440	Pass
11441	Pass	11442	Pass	11443	Pass	11444	Pass
11445	Pass	11446	Pass	11447	Pass	11448	Pass
11449	Pass	11450	Pass	11451	Pass	11452	Pass
11453	Pass	11454	Pass	11455	Pass	11456	Pass
11457	Pass	11458	Pass	11459	Pass	11460	Pass
11461	Pass	11462	Pass	11463	Pass	11464	Pass
11465	Pass	11466	Pass	11467	Pass	11468	Pass
11469	Pass	11470	Pass	11471	Pass	11472	Pass
11473	Pass	11474	Pass	11475	Pass	11476	Pass
11477	Pass	11478	Pass	11479	Pass	11480	Pass
11481	Pass	11482	Pass	11483	Pass	11484	Pass
11485	Pass	11486	Pass	11487	Pass	11488	Pass
11489	Pass	11490	Pass	11491	Pass	11492	Pass
11493	Pass	11494	Pass	11495	Pass	11496	Pass
11497	Pass	11498	Pass	11499	Pass	11500	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory