

# HYDRO PRESSURE TEST

|                                   |                                                                 |                  |
|-----------------------------------|-----------------------------------------------------------------|------------------|
| TC No.: HPT/A6/A50/RQ/242/25      | Model No.: KFARQ-6-50%                                          | Date: 21-07-2025 |
| Type and Capacity of Extinguisher | : KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg. |                  |
| Batch Number                      | : KFARQ50%6 242/25                                              |                  |
| Batch Quantity                    | : 101.00 Nos.                                                   |                  |
| Serial Numbers                    | : 24101 To 24200 And 24105A                                     |                  |
| Month of Manufacturing            | : Jul/25                                                        |                  |

| Sr. Nos.                                                      | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|---------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 24105A and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 24101                                                         | Pass   | 24102    | Pass   | 24103    | Pass   | 24104    | Pass   |
| 24105                                                         | Pass   | 24106    | Pass   | 24107    | Pass   | 24108    | Pass   |
| 24109                                                         | Pass   | 24110    | Pass   | 24111    | Pass   | 24112    | Pass   |
| 24113                                                         | Pass   | 24114    | Pass   | 24115    | Pass   | 24116    | Pass   |
| 24117                                                         | Pass   | 24118    | Pass   | 24119    | Pass   | 24120    | Pass   |
| 24121                                                         | Pass   | 24122    | Pass   | 24123    | Pass   | 24124    | Pass   |
| 24125                                                         | Pass   | 24126    | Pass   | 24127    | Pass   | 24128    | Pass   |
| 24129                                                         | Pass   | 24130    | Pass   | 24131    | Pass   | 24132    | Pass   |
| 24133                                                         | Pass   | 24134    | Pass   | 24135    | Pass   | 24136    | Pass   |
| 24137                                                         | Pass   | 24138    | Pass   | 24139    | Pass   | 24140    | Pass   |
| 24141                                                         | Pass   | 24142    | Pass   | 24143    | Pass   | 24144    | Pass   |
| 24145                                                         | Pass   | 24146    | Pass   | 24147    | Pass   | 24148    | Pass   |
| 24149                                                         | Pass   | 24150    | Pass   | 24151    | Pass   | 24152    | Pass   |
| 24153                                                         | Pass   | 24154    | Pass   | 24155    | Pass   | 24156    | Pass   |
| 24157                                                         | Pass   | 24158    | Pass   | 24159    | Pass   | 24160    | Pass   |
| 24161                                                         | Pass   | 24162    | Pass   | 24163    | Pass   | 24164    | Pass   |
| 24165                                                         | Pass   | 24166    | Pass   | 24167    | Pass   | 24168    | Pass   |
| 24169                                                         | Pass   | 24170    | Pass   | 24171    | Pass   | 24172    | Pass   |
| 24173                                                         | Pass   | 24174    | Pass   | 24175    | Pass   | 24176    | Pass   |
| 24177                                                         | Pass   | 24178    | Pass   | 24179    | Pass   | 24180    | Pass   |
| 24181                                                         | Pass   | 24182    | Pass   | 24183    | Pass   | 24184    | Pass   |
| 24185                                                         | Pass   | 24186    | Pass   | 24187    | Pass   | 24188    | Pass   |
| 24189                                                         | Pass   | 24190    | Pass   | 24191    | Pass   | 24192    | Pass   |
| 24193                                                         | Pass   | 24194    | Pass   | 24195    | Pass   | 24196    | Pass   |
| 24197                                                         | Pass   | 24198    | Pass   | 24199    | Pass   | 24200    | Pass   |

**Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.**



**Authorized Signatory**