

HYDRO PRESSURE TEST

TC No.: HPT/MOD5/CA/RQ/062/25	Model No.: KMCRQ-5	Date: 18-09-2025
Type and Capacity of Extinguisher	: KMCRQ-5-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 5 Kg.	
Batch Number	: KMCRQ5 062/25	
Batch Quantity	: 50.00 Nos.	
Serial Numbers	: 03051 To 3100	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 03051 To 3100 and removed from the Lot/Batch							
3051	Pass	3052	Pass	3053	Pass	3054	Pass
3055	Pass	3056	Pass	3057	Pass	3058	Pass
3059	Pass	3060	Pass	3061	Pass	3062	Pass
3063	Pass	3064	Pass	3065	Pass	3066	Pass
3067	Pass	3068	Pass	3069	Pass	3070	Pass
3071	Pass	3072	Pass	3073	Pass	3074	Pass
3075	Pass	3076	Pass	3077	Pass	3078	Pass
3079	Pass	3080	Pass	3081	Pass	3082	Pass
3083	Pass	3084	Pass	3085	Pass	3086	Pass
3087	Pass	3088	Pass	3089	Pass	3090	Pass
3091	Pass	3092	Pass	3093	Pass	3094	Pass
3095	Pass	3096	Pass	3097	Pass	3098	Pass
3099	Pass	3100	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory