

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/254/25	Model No.: MARQ-6-50%	Date: 03-08-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 254/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 25301 To 25400 And 25305A	
Month of Manufacturing	: Aug/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 25305A and removed from the Lot/Batch							
25301	Pass	25302	Pass	25303	Pass	25304	Pass
25305	Pass	25306	Pass	25307	Pass	25308	Pass
25309	Pass	25310	Pass	25311	Pass	25312	Pass
25313	Pass	25314	Pass	25315	Pass	25316	Pass
25317	Pass	25318	Pass	25319	Pass	25320	Pass
25321	Pass	25322	Pass	25323	Pass	25324	Pass
25325	Pass	25326	Pass	25327	Pass	25328	Pass
25329	Pass	25330	Pass	25331	Pass	25332	Pass
25333	Pass	25334	Pass	25335	Pass	25336	Pass
25337	Pass	25338	Pass	25339	Pass	25340	Pass
25341	Pass	25342	Pass	25343	Pass	25344	Pass
25345	Pass	25346	Pass	25347	Pass	25348	Pass
25349	Pass	25350	Pass	25351	Pass	25352	Pass
25353	Pass	25354	Pass	25355	Pass	25356	Pass
25357	Pass	25358	Pass	25359	Pass	25360	Pass
25361	Pass	25362	Pass	25363	Pass	25364	Pass
25365	Pass	25366	Pass	25367	Pass	25368	Pass
25369	Pass	25370	Pass	25371	Pass	25372	Pass
25373	Pass	25374	Pass	25375	Pass	25376	Pass
25377	Pass	25378	Pass	25379	Pass	25380	Pass
25381	Pass	25382	Pass	25383	Pass	25384	Pass
25385	Pass	25386	Pass	25387	Pass	25388	Pass
25389	Pass	25390	Pass	25391	Pass	25392	Pass
25393	Pass	25394	Pass	25395	Pass	25396	Pass
25397	Pass	25398	Pass	25399	Pass	25400	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory