

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/259/25	Model No.: MARQ-6-50%	Date: 03-08-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 259/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 25801 To 25900 And 25805A	
Month of Manufacturing	: Aug/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 25805A and removed from the Lot/Batch							
25801	Pass	25802	Pass	25803	Pass	25804	Pass
25805	Pass	25806	Pass	25807	Pass	25808	Pass
25809	Pass	25810	Pass	25811	Pass	25812	Pass
25813	Pass	25814	Pass	25815	Pass	25816	Pass
25817	Pass	25818	Pass	25819	Pass	25820	Pass
25821	Pass	25822	Pass	25823	Pass	25824	Pass
25825	Pass	25826	Pass	25827	Pass	25828	Pass
25829	Pass	25830	Pass	25831	Pass	25832	Pass
25833	Pass	25834	Pass	25835	Pass	25836	Pass
25837	Pass	25838	Pass	25839	Pass	25840	Pass
25841	Pass	25842	Pass	25843	Pass	25844	Pass
25845	Pass	25846	Pass	25847	Pass	25848	Pass
25849	Pass	25850	Pass	25851	Pass	25852	Pass
25853	Pass	25854	Pass	25855	Pass	25856	Pass
25857	Pass	25858	Pass	25859	Pass	25860	Pass
25861	Pass	25862	Pass	25863	Pass	25864	Pass
25865	Pass	25866	Pass	25867	Pass	25868	Pass
25869	Pass	25870	Pass	25871	Pass	25872	Pass
25873	Pass	25874	Pass	25875	Pass	25876	Pass
25877	Pass	25878	Pass	25879	Pass	25880	Pass
25881	Pass	25882	Pass	25883	Pass	25884	Pass
25885	Pass	25886	Pass	25887	Pass	25888	Pass
25889	Pass	25890	Pass	25891	Pass	25892	Pass
25893	Pass	25894	Pass	25895	Pass	25896	Pass
25897	Pass	25898	Pass	25899	Pass	25900	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory