

HYDRO PRESSURE TEST

TC No.: HPT/A6/S/RQ/023/25	Model No.: KFSRQ-6-S	Date: 24-07-2025
Type and Capacity of Extinguisher	: KFSRQ-6-S-Kanex BC Dry Powder (SBC) SP Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFSRQ6S 023/25	
Batch Quantity	: 51.00 Nos.	
Serial Numbers	: 01101 To 1150 And 1105A	
Month of Manufacturing	: Jul/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 1105A and removed from the Lot/Batch							
1101	Pass	1102	Pass	1103	Pass	1104	Pass
1105	Pass	1106	Pass	1107	Pass	1108	Pass
1109	Pass	1110	Pass	1111	Pass	1112	Pass
1113	Pass	1114	Pass	1115	Pass	1116	Pass
1117	Pass	1118	Pass	1119	Pass	1120	Pass
1121	Pass	1122	Pass	1123	Pass	1124	Pass
1125	Pass	1126	Pass	1127	Pass	1128	Pass
1129	Pass	1130	Pass	1131	Pass	1132	Pass
1133	Pass	1134	Pass	1135	Pass	1136	Pass
1137	Pass	1138	Pass	1139	Pass	1140	Pass
1141	Pass	1142	Pass	1143	Pass	1144	Pass
1145	Pass	1146	Pass	1147	Pass	1148	Pass
1149	Pass	1150	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory