

HYDRO PRESSURE TEST

TC No.: HPT/MOD2/A90/RQ/012/25	Model No.: KMPRQ-2-90%	Date: 24-05-2025
Type and Capacity of Extinguisher	: KMPRQ-2-90%-Kanex Modular ABC Dry Powder Fire Extinguisher Cap. 2 Kg.	
Batch Number	: KMPRQ90%2 012/25	
Batch Quantity	: 20.00 Nos.	
Serial Numbers	: 00221 To 240	
Month of Manufacturing	: May/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 00221 To 240 and removed from the Lot/Batch							
221	Pass	222	Pass	223	Pass	224	Pass
225	Pass	226	Pass	227	Pass	228	Pass
229	Pass	230	Pass	231	Pass	232	Pass
233	Pass	234	Pass	235	Pass	236	Pass
237	Pass	238	Pass	239	Pass	240	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory