

HELIUM LEAK DETECTION TEST

TC No.: HLD/KF/LI/HQ2/003/25	Model No.: KFLIHQ-2	Date: 15-07-2025
Type and Capacity of Extinguisher	: KFLIHQ-2-Lithium-Ion (AVD) Stored Pressure Fire Extinguisher 2 Ltr	
Batch Number	: KFLIHQ2 003/25	
Batch Quantity	: 50 Nos.	
Serial Numbers	: 00101 To 150	
Month of Manufacturing	: Jul/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
101	Pass	102	Pass	103	Pass	104	Pass
105	Pass	106	Pass	107	Pass	108	Pass
109	Pass	110	Pass	111	Pass	112	Pass
113	Pass	114	Pass	115	Pass	116	Pass
117	Pass	118	Pass	119	Pass	120	Pass
121	Pass	122	Pass	123	Pass	124	Pass
125	Pass	126	Pass	127	Pass	128	Pass
129	Pass	130	Pass	131	Pass	132	Pass
133	Pass	134	Pass	135	Pass	136	Pass
137	Pass	138	Pass	139	Pass	140	Pass
141	Pass	142	Pass	143	Pass	144	Pass
145	Pass	146	Pass	147	Pass	148	Pass
149	Pass	150	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers has been tested on Mass Spectrometer Helium Leak Detector, with test pressure of 1 mbar and desired leak rate of 1×10^{-6} mbar.l/sec and no any cylinders shows leakage beyond this limit.



Authorized Signatory