

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/286/25	Model No.: MARQ-6-50%	Date: 13-09-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 286/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 28501 To 28600 And 28505A	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 28505A and removed from the Lot/Batch							
28501	Pass	28502	Pass	28503	Pass	28504	Pass
28505	Pass	28506	Pass	28507	Pass	28508	Pass
28509	Pass	28510	Pass	28511	Pass	28512	Pass
28513	Pass	28514	Pass	28515	Pass	28516	Pass
28517	Pass	28518	Pass	28519	Pass	28520	Pass
28521	Pass	28522	Pass	28523	Pass	28524	Pass
28525	Pass	28526	Pass	28527	Pass	28528	Pass
28529	Pass	28530	Pass	28531	Pass	28532	Pass
28533	Pass	28534	Pass	28535	Pass	28536	Pass
28537	Pass	28538	Pass	28539	Pass	28540	Pass
28541	Pass	28542	Pass	28543	Pass	28544	Pass
28545	Pass	28546	Pass	28547	Pass	28548	Pass
28549	Pass	28550	Pass	28551	Pass	28552	Pass
28553	Pass	28554	Pass	28555	Pass	28556	Pass
28557	Pass	28558	Pass	28559	Pass	28560	Pass
28561	Pass	28562	Pass	28563	Pass	28564	Pass
28565	Pass	28566	Pass	28567	Pass	28568	Pass
28569	Pass	28570	Pass	28571	Pass	28572	Pass
28573	Pass	28574	Pass	28575	Pass	28576	Pass
28577	Pass	28578	Pass	28579	Pass	28580	Pass
28581	Pass	28582	Pass	28583	Pass	28584	Pass
28585	Pass	28586	Pass	28587	Pass	28588	Pass
28589	Pass	28590	Pass	28591	Pass	28592	Pass
28593	Pass	28594	Pass	28595	Pass	28596	Pass
28597	Pass	28598	Pass	28599	Pass	28600	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory