



# Kanex Fire Solutions Ltd.

Plot No. 7, Paras Industrial Estate, Near Garibsha Pir, Sihor-364240



## MANUFACTURER TEST CERTIFICATE

| Parameters                 | Required Specifications (Internal) | Observed        | Remarks      |
|----------------------------|------------------------------------|-----------------|--------------|
| Fire Buckets               |                                    |                 |              |
| Extinguishing Agent        | Sand/Water                         |                 |              |
| Water capacity             | 9/10 Ltr.                          |                 |              |
| Dimension Report           |                                    |                 |              |
| Major Dia. Of bucket       | 300 mm. (±10)                      | 296 to 298 mm.  | Satisfactory |
| Minor Dia. Of bucket       | 190 mm. (±10)                      | 190 to192 mm.   | Satisfactory |
| Total Height of bucket     | 260 mm. (±10)                      | 265 to 267 mm.  | Satisfactory |
| Sheet thickness of Buckets | 0.7 mm.                            | 0.75 to 0.8 mm. | Satisfactory |
| Weight                     | 1 Kg.                              | 1 to 1.05 kg.   | Satisfactory |

**Materials of Construction:** Meets the internal standard requirements.

**Painting:** Internal part of bucket painted in White & external part with PO/Fire Red color.

### **Fire Bucket Stand**

Stand dimensions, Materials of Construction and Painting meets the Customer requirements.

**Painting:** Painted with PO/Fire Red color.

### **Remarks:**

**Observations made as above for Fire Buckets and stands meets the client requirements.**



For Kanex Fire Solutions Ltd.  
Aditya Trivedi (Technical)