



Warranty Certificate

Date: 29-09-2025**Manufacturer:** Kanex Fire Solutions Limited.**Customer Name:** Larsen & Toubro Limited**Warranty Start Date:** 29-09-2025**Warranty End Date:** 28-09-2026.

This is to certify that the below extinguishers are warranted for a period of **1** year from the date of supply against any of Manufacturing/Quality defects.

NOTE – IF TAMPER SEAL IS NOT INTACT, THE WARRANTY SHALL BE CONSIDERED VOID.

Sr.No.	Type & Capacity of Extinguishers	Quantity	Sr. Nos.
1	KMPRQ-2-50%-Kanex Modular ABC Dry Powder Fire Extinguisher Cap. 2 Kg.	25	As Per Annexure – I

Also certify that, all the Fire extinguishers supplied against Invoice No. **25-26/K/004272 Dated: 29-09-2025 P.O.No. 4400000219** are hydraulically tested 100% at 35 bar except CO2 and randomly tested for performance test. All the extinguishers confirms to IS 15683:2018 (Portable) or IS 16018:2012 (Mobile) requirements.

Note : If applicable CO2 Cylinders are PESO approved & HPT tested at 225 bar by Cylinder Manufacturer.

**Authorized Signatory**