

HYDRO PRESSURE TEST

TC No.: HPT/MOD2/A50/RQ/014/25	Model No.: KMPRQ-2-50%	Date: 27-08-2025
Type and Capacity of Extinguisher	: KMPRQ-2-50%-Kanex Modular ABC Dry Powder Fire Extinguisher Cap. 2 Kg.	
Batch Number	: KMPRQ50%2 014/25	
Batch Quantity	: 20.00 Nos.	
Serial Numbers	: 00261 To 280	
Month of Manufacturing	: Aug/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 00261 To 280 and removed from the Lot/Batch							
261	Pass	262	Pass	263	Pass	264	Pass
265	Pass	266	Pass	267	Pass	268	Pass
269	Pass	270	Pass	271	Pass	272	Pass
273	Pass	274	Pass	275	Pass	276	Pass
277	Pass	278	Pass	279	Pass	280	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory