

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/285/25	Model No.: MARQ-6-50%	Date: 13-09-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 285/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 28401 To 28500 And 28405A	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 28405A and removed from the Lot/Batch							
28401	Pass	28402	Pass	28403	Pass	28404	Pass
28405	Pass	28406	Pass	28407	Pass	28408	Pass
28409	Pass	28410	Pass	28411	Pass	28412	Pass
28413	Pass	28414	Pass	28415	Pass	28416	Pass
28417	Pass	28418	Pass	28419	Pass	28420	Pass
28421	Pass	28422	Pass	28423	Pass	28424	Pass
28425	Pass	28426	Pass	28427	Pass	28428	Pass
28429	Pass	28430	Pass	28431	Pass	28432	Pass
28433	Pass	28434	Pass	28435	Pass	28436	Pass
28437	Pass	28438	Pass	28439	Pass	28440	Pass
28441	Pass	28442	Pass	28443	Pass	28444	Pass
28445	Pass	28446	Pass	28447	Pass	28448	Pass
28449	Pass	28450	Pass	28451	Pass	28452	Pass
28453	Pass	28454	Pass	28455	Pass	28456	Pass
28457	Pass	28458	Pass	28459	Pass	28460	Pass
28461	Pass	28462	Pass	28463	Pass	28464	Pass
28465	Pass	28466	Pass	28467	Pass	28468	Pass
28469	Pass	28470	Pass	28471	Pass	28472	Pass
28473	Pass	28474	Pass	28475	Pass	28476	Pass
28477	Pass	28478	Pass	28479	Pass	28480	Pass
28481	Pass	28482	Pass	28483	Pass	28484	Pass
28485	Pass	28486	Pass	28487	Pass	28488	Pass
28489	Pass	28490	Pass	28491	Pass	28492	Pass
28493	Pass	28494	Pass	28495	Pass	28496	Pass
28497	Pass	28498	Pass	28499	Pass	28500	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory