

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/287/25	Model No.: MARQ-6-50%	Date: 13-09-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 287/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 28601 To 28700 And 28605A	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 28605A and removed from the Lot/Batch							
28601	Pass	28602	Pass	28603	Pass	28604	Pass
28605	Pass	28606	Pass	28607	Pass	28608	Pass
28609	Pass	28610	Pass	28611	Pass	28612	Pass
28613	Pass	28614	Pass	28615	Pass	28616	Pass
28617	Pass	28618	Pass	28619	Pass	28620	Pass
28621	Pass	28622	Pass	28623	Pass	28624	Pass
28625	Pass	28626	Pass	28627	Pass	28628	Pass
28629	Pass	28630	Pass	28631	Pass	28632	Pass
28633	Pass	28634	Pass	28635	Pass	28636	Pass
28637	Pass	28638	Pass	28639	Pass	28640	Pass
28641	Pass	28642	Pass	28643	Pass	28644	Pass
28645	Pass	28646	Pass	28647	Pass	28648	Pass
28649	Pass	28650	Pass	28651	Pass	28652	Pass
28653	Pass	28654	Pass	28655	Pass	28656	Pass
28657	Pass	28658	Pass	28659	Pass	28660	Pass
28661	Pass	28662	Pass	28663	Pass	28664	Pass
28665	Pass	28666	Pass	28667	Pass	28668	Pass
28669	Pass	28670	Pass	28671	Pass	28672	Pass
28673	Pass	28674	Pass	28675	Pass	28676	Pass
28677	Pass	28678	Pass	28679	Pass	28680	Pass
28681	Pass	28682	Pass	28683	Pass	28684	Pass
28685	Pass	28686	Pass	28687	Pass	28688	Pass
28689	Pass	28690	Pass	28691	Pass	28692	Pass
28693	Pass	28694	Pass	28695	Pass	28696	Pass
28697	Pass	28698	Pass	28699	Pass	28700	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory