

# HYDRO PRESSURE TEST

|                                   |                                                                |                  |
|-----------------------------------|----------------------------------------------------------------|------------------|
| TC No.: HPT/MA6/A40/RQ/288/25     | Model No.: MARQ-6-50%                                          | Date: 13-09-2025 |
| Type and Capacity of Extinguisher | : MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg. |                  |
| Batch Number                      | : MARQ50%6 288/25                                              |                  |
| Batch Quantity                    | : 101.00 Nos.                                                  |                  |
| Serial Numbers                    | : 28701 To 28800 And 28705A                                    |                  |
| Month of Manufacturing            | : Sep/25                                                       |                  |

| Sr. Nos.                                                      | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|---------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 28705A and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 28701                                                         | Pass   | 28702    | Pass   | 28703    | Pass   | 28704    | Pass   |
| 28705                                                         | Pass   | 28706    | Pass   | 28707    | Pass   | 28708    | Pass   |
| 28709                                                         | Pass   | 28710    | Pass   | 28711    | Pass   | 28712    | Pass   |
| 28713                                                         | Pass   | 28714    | Pass   | 28715    | Pass   | 28716    | Pass   |
| 28717                                                         | Pass   | 28718    | Pass   | 28719    | Pass   | 28720    | Pass   |
| 28721                                                         | Pass   | 28722    | Pass   | 28723    | Pass   | 28724    | Pass   |
| 28725                                                         | Pass   | 28726    | Pass   | 28727    | Pass   | 28728    | Pass   |
| 28729                                                         | Pass   | 28730    | Pass   | 28731    | Pass   | 28732    | Pass   |
| 28733                                                         | Pass   | 28734    | Pass   | 28735    | Pass   | 28736    | Pass   |
| 28737                                                         | Pass   | 28738    | Pass   | 28739    | Pass   | 28740    | Pass   |
| 28741                                                         | Pass   | 28742    | Pass   | 28743    | Pass   | 28744    | Pass   |
| 28745                                                         | Pass   | 28746    | Pass   | 28747    | Pass   | 28748    | Pass   |
| 28749                                                         | Pass   | 28750    | Pass   | 28751    | Pass   | 28752    | Pass   |
| 28753                                                         | Pass   | 28754    | Pass   | 28755    | Pass   | 28756    | Pass   |
| 28757                                                         | Pass   | 28758    | Pass   | 28759    | Pass   | 28760    | Pass   |
| 28761                                                         | Pass   | 28762    | Pass   | 28763    | Pass   | 28764    | Pass   |
| 28765                                                         | Pass   | 28766    | Pass   | 28767    | Pass   | 28768    | Pass   |
| 28769                                                         | Pass   | 28770    | Pass   | 28771    | Pass   | 28772    | Pass   |
| 28773                                                         | Pass   | 28774    | Pass   | 28775    | Pass   | 28776    | Pass   |
| 28777                                                         | Pass   | 28778    | Pass   | 28779    | Pass   | 28780    | Pass   |
| 28781                                                         | Pass   | 28782    | Pass   | 28783    | Pass   | 28784    | Pass   |
| 28785                                                         | Pass   | 28786    | Pass   | 28787    | Pass   | 28788    | Pass   |
| 28789                                                         | Pass   | 28790    | Pass   | 28791    | Pass   | 28792    | Pass   |
| 28793                                                         | Pass   | 28794    | Pass   | 28795    | Pass   | 28796    | Pass   |
| 28797                                                         | Pass   | 28798    | Pass   | 28799    | Pass   | 28800    | Pass   |

**Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.**



**Authorized Signatory**