

HYDRO PRESSURE TEST

TC No.: HPT/CA6/RQ/006/25	Model No.: KCARQ-6	Date: 18-05-2025
Type and Capacity of Extinguisher	: KCARQ-6-Kanex Clean Agent HFC Based Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KCARQ6 006/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 00501 To 600 And 505A	
Month of Manufacturing	: May/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 505A and removed from the Lot/Batch							
501	Pass	502	Pass	503	Pass	504	Pass
505	Pass	506	Pass	507	Pass	508	Pass
509	Pass	510	Pass	511	Pass	512	Pass
513	Pass	514	Pass	515	Pass	516	Pass
517	Pass	518	Pass	519	Pass	520	Pass
521	Pass	522	Pass	523	Pass	524	Pass
525	Pass	526	Pass	527	Pass	528	Pass
529	Pass	530	Pass	531	Pass	532	Pass
533	Pass	534	Pass	535	Pass	536	Pass
537	Pass	538	Pass	539	Pass	540	Pass
541	Pass	542	Pass	543	Pass	544	Pass
545	Pass	546	Pass	547	Pass	548	Pass
549	Pass	550	Pass	551	Pass	552	Pass
553	Pass	554	Pass	555	Pass	556	Pass
557	Pass	558	Pass	559	Pass	560	Pass
561	Pass	562	Pass	563	Pass	564	Pass
565	Pass	566	Pass	567	Pass	568	Pass
569	Pass	570	Pass	571	Pass	572	Pass
573	Pass	574	Pass	575	Pass	576	Pass
577	Pass	578	Pass	579	Pass	580	Pass
581	Pass	582	Pass	583	Pass	584	Pass
585	Pass	586	Pass	587	Pass	588	Pass
589	Pass	590	Pass	591	Pass	592	Pass
593	Pass	594	Pass	595	Pass	596	Pass
597	Pass	598	Pass	599	Pass	600	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory