

HYDRO PRESSURE TEST

TC No.: HPT/A6/A90/RQ/245/25	Model No.: KFARQ-6-90%	Date: 07-09-2025
Type and Capacity of Extinguisher	: KFARQ-6-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ90%6 245/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 24401 To 24500 And 24405A	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 24405A and removed from the Lot/Batch							
24401	Pass	24402	Pass	24403	Pass	24404	Pass
24405	Pass	24406	Pass	24407	Pass	24408	Pass
24409	Pass	24410	Pass	24411	Pass	24412	Pass
24413	Pass	24414	Pass	24415	Pass	24416	Pass
24417	Pass	24418	Pass	24419	Pass	24420	Pass
24421	Pass	24422	Pass	24423	Pass	24424	Pass
24425	Pass	24426	Pass	24427	Pass	24428	Pass
24429	Pass	24430	Pass	24431	Pass	24432	Pass
24433	Pass	24434	Pass	24435	Pass	24436	Pass
24437	Pass	24438	Pass	24439	Pass	24440	Pass
24441	Pass	24442	Pass	24443	Pass	24444	Pass
24445	Pass	24446	Pass	24447	Pass	24448	Pass
24449	Pass	24450	Pass	24451	Pass	24452	Pass
24453	Pass	24454	Pass	24455	Pass	24456	Pass
24457	Pass	24458	Pass	24459	Pass	24460	Pass
24461	Pass	24462	Pass	24463	Pass	24464	Pass
24465	Pass	24466	Pass	24467	Pass	24468	Pass
24469	Pass	24470	Pass	24471	Pass	24472	Pass
24473	Pass	24474	Pass	24475	Pass	24476	Pass
24477	Pass	24478	Pass	24479	Pass	24480	Pass
24481	Pass	24482	Pass	24483	Pass	24484	Pass
24485	Pass	24486	Pass	24487	Pass	24488	Pass
24489	Pass	24490	Pass	24491	Pass	24492	Pass
24493	Pass	24494	Pass	24495	Pass	24496	Pass
24497	Pass	24498	Pass	24499	Pass	24500	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory