

HYDRO PRESSURE TEST

TC No.: HPT/D25/A50/RQ/012/25	Model No.: KFDRQ-25-50%	Date: 08-09-2025
Type and Capacity of Extinguisher	: KFDRQ-25-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 25 Kg.	
Batch Number	: KFDRQ50%25 012/25	
Batch Quantity	: 50.00 Nos.	
Serial Numbers	: 00551 To 600	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on Cylinder Sr.No.505A and which is removed from the batch (11th batch)							
551	Pass	552	Pass	553	Pass	554	Pass
555	Pass	556	Pass	557	Pass	558	Pass
559	Pass	560	Pass	561	Pass	562	Pass
563	Pass	564	Pass	565	Pass	566	Pass
567	Pass	568	Pass	569	Pass	570	Pass
571	Pass	572	Pass	573	Pass	574	Pass
575	Pass	576	Pass	577	Pass	578	Pass
579	Pass	580	Pass	581	Pass	582	Pass
583	Pass	584	Pass	585	Pass	586	Pass
587	Pass	588	Pass	589	Pass	590	Pass
591	Pass	592	Pass	593	Pass	594	Pass
595	Pass	596	Pass	597	Pass	598	Pass
599	Pass	600	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 Minute and found satisfactory. No any leakage observed.



Authorized Signatory