

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/262/25	Model No.: MARQ-6-50%	Date: 09-08-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 262/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 26101 To 26200 And 26105A	
Month of Manufacturing	: Aug/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 26105A and removed from the Lot/Batch							
26101	Pass	26102	Pass	26103	Pass	26104	Pass
26105	Pass	26106	Pass	26107	Pass	26108	Pass
26109	Pass	26110	Pass	26111	Pass	26112	Pass
26113	Pass	26114	Pass	26115	Pass	26116	Pass
26117	Pass	26118	Pass	26119	Pass	26120	Pass
26121	Pass	26122	Pass	26123	Pass	26124	Pass
26125	Pass	26126	Pass	26127	Pass	26128	Pass
26129	Pass	26130	Pass	26131	Pass	26132	Pass
26133	Pass	26134	Pass	26135	Pass	26136	Pass
26137	Pass	26138	Pass	26139	Pass	26140	Pass
26141	Pass	26142	Pass	26143	Pass	26144	Pass
26145	Pass	26146	Pass	26147	Pass	26148	Pass
26149	Pass	26150	Pass	26151	Pass	26152	Pass
26153	Pass	26154	Pass	26155	Pass	26156	Pass
26157	Pass	26158	Pass	26159	Pass	26160	Pass
26161	Pass	26162	Pass	26163	Pass	26164	Pass
26165	Pass	26166	Pass	26167	Pass	26168	Pass
26169	Pass	26170	Pass	26171	Pass	26172	Pass
26173	Pass	26174	Pass	26175	Pass	26176	Pass
26177	Pass	26178	Pass	26179	Pass	26180	Pass
26181	Pass	26182	Pass	26183	Pass	26184	Pass
26185	Pass	26186	Pass	26187	Pass	26188	Pass
26189	Pass	26190	Pass	26191	Pass	26192	Pass
26193	Pass	26194	Pass	26195	Pass	26196	Pass
26197	Pass	26198	Pass	26199	Pass	26200	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory