

**HYDRO PRESSURE TEST**

TC No.: HPT/A9/K/HQ/037/25

Model No.: KFKHQ-9

Date: 11-09-2025

Type and Capacity of Extinguisher : KFKHQ-9-Kanex F Class Kitchen Fire Extinguisher Cap. 9 Ltr.

Batch Number : KFKHQ9 037/25

Batch Quantity : 10.00 Nos.

Serial Numbers : 00361 To 370

Month of Manufacturing : Sep/25

| Sr. Nos.                                                            | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|---------------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 00361 To 370 and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 361                                                                 | Pass   | 362      | Pass   | 363      | Pass   | 364      | Pass   |
| 365                                                                 | Pass   | 366      | Pass   | 367      | Pass   | 368      | Pass   |
| 369                                                                 | Pass   | 370      | Pass   |          |        |          |        |

**Remarks:** This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.

**Authorized Signatory**