

HYDRO PRESSURE TEST

TC No.: HPT/MA4/A40/RQ/048/25	Model No.: MARQ-4-40%	Date: 04-09-2025
Type and Capacity of Extinguisher	: MARQ-4-40%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg.	
Batch Number	: MARQ40%4 048/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 04701 To 4800 And 4705A	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 4705A and removed from the Lot/Batch							
4701	Pass	4702	Pass	4703	Pass	4704	Pass
4705	Pass	4706	Pass	4707	Pass	4708	Pass
4709	Pass	4710	Pass	4711	Pass	4712	Pass
4713	Pass	4714	Pass	4715	Pass	4716	Pass
4717	Pass	4718	Pass	4719	Pass	4720	Pass
4721	Pass	4722	Pass	4723	Pass	4724	Pass
4725	Pass	4726	Pass	4727	Pass	4728	Pass
4729	Pass	4730	Pass	4731	Pass	4732	Pass
4733	Pass	4734	Pass	4735	Pass	4736	Pass
4737	Pass	4738	Pass	4739	Pass	4740	Pass
4741	Pass	4742	Pass	4743	Pass	4744	Pass
4745	Pass	4746	Pass	4747	Pass	4748	Pass
4749	Pass	4750	Pass	4751	Pass	4752	Pass
4753	Pass	4754	Pass	4755	Pass	4756	Pass
4757	Pass	4758	Pass	4759	Pass	4760	Pass
4761	Pass	4762	Pass	4763	Pass	4764	Pass
4765	Pass	4766	Pass	4767	Pass	4768	Pass
4769	Pass	4770	Pass	4771	Pass	4772	Pass
4773	Pass	4774	Pass	4775	Pass	4776	Pass
4777	Pass	4778	Pass	4779	Pass	4780	Pass
4781	Pass	4782	Pass	4783	Pass	4784	Pass
4785	Pass	4786	Pass	4787	Pass	4788	Pass
4789	Pass	4790	Pass	4791	Pass	4792	Pass
4793	Pass	4794	Pass	4795	Pass	4796	Pass
4797	Pass	4798	Pass	4799	Pass	4800	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory