

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/210/25	Model No.: MARQ-6-50%	Date: 26-06-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 210/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 20901 To 21000 And 20905A	
Month of Manufacturing	: Jun/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 20905A and removed from the Lot/Batch							
20901	Pass	20902	Pass	20903	Pass	20904	Pass
20905	Pass	20906	Pass	20907	Pass	20908	Pass
20909	Pass	20910	Pass	20911	Pass	20912	Pass
20913	Pass	20914	Pass	20915	Pass	20916	Pass
20917	Pass	20918	Pass	20919	Pass	20920	Pass
20921	Pass	20922	Pass	20923	Pass	20924	Pass
20925	Pass	20926	Pass	20927	Pass	20928	Pass
20929	Pass	20930	Pass	20931	Pass	20932	Pass
20933	Pass	20934	Pass	20935	Pass	20936	Pass
20937	Pass	20938	Pass	20939	Pass	20940	Pass
20941	Pass	20942	Pass	20943	Pass	20944	Pass
20945	Pass	20946	Pass	20947	Pass	20948	Pass
20949	Pass	20950	Pass	20951	Pass	20952	Pass
20953	Pass	20954	Pass	20955	Pass	20956	Pass
20957	Pass	20958	Pass	20959	Pass	20960	Pass
20961	Pass	20962	Pass	20963	Pass	20964	Pass
20965	Pass	20966	Pass	20967	Pass	20968	Pass
20969	Pass	20970	Pass	20971	Pass	20972	Pass
20973	Pass	20974	Pass	20975	Pass	20976	Pass
20977	Pass	20978	Pass	20979	Pass	20980	Pass
20981	Pass	20982	Pass	20983	Pass	20984	Pass
20985	Pass	20986	Pass	20987	Pass	20988	Pass
20989	Pass	20990	Pass	20991	Pass	20992	Pass
20993	Pass	20994	Pass	20995	Pass	20996	Pass
20997	Pass	20998	Pass	20999	Pass	21000	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory