

HYDRO PRESSURE TEST

TC No.: HPT/MOD10/CA/RQ/132/25	Model No.: KMCRQ-10	Date: 11-09-2025
Type and Capacity of Extinguisher	: KMCRQ-10-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 10 Kg.	
Batch Number	: KMCRQ10 132/25	
Batch Quantity	: 10.00 Nos.	
Serial Numbers	: 01311 To 1320	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 01311 To 1320 and removed from the Lot/Batch							
1311	Pass	1312	Pass	1313	Pass	1314	Pass
1315	Pass	1316	Pass	1317	Pass	1318	Pass
1319	Pass	1320	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory