

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/267/25	Model No.: KFARQ-6-50%	Date: 18-08-2025
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 267/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 26601 To 26700 And 26605A	
Month of Manufacturing	: Aug/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 26605A and removed from the Lot/Batch							
26601	Pass	26602	Pass	26603	Pass	26604	Pass
26605	Pass	26606	Pass	26607	Pass	26608	Pass
26609	Pass	26610	Pass	26611	Pass	26612	Pass
26613	Pass	26614	Pass	26615	Pass	26616	Pass
26617	Pass	26618	Pass	26619	Pass	26620	Pass
26621	Pass	26622	Pass	26623	Pass	26624	Pass
26625	Pass	26626	Pass	26627	Pass	26628	Pass
26629	Pass	26630	Pass	26631	Pass	26632	Pass
26633	Pass	26634	Pass	26635	Pass	26636	Pass
26637	Pass	26638	Pass	26639	Pass	26640	Pass
26641	Pass	26642	Pass	26643	Pass	26644	Pass
26645	Pass	26646	Pass	26647	Pass	26648	Pass
26649	Pass	26650	Pass	26651	Pass	26652	Pass
26653	Pass	26654	Pass	26655	Pass	26656	Pass
26657	Pass	26658	Pass	26659	Pass	26660	Pass
26661	Pass	26662	Pass	26663	Pass	26664	Pass
26665	Pass	26666	Pass	26667	Pass	26668	Pass
26669	Pass	26670	Pass	26671	Pass	26672	Pass
26673	Pass	26674	Pass	26675	Pass	26676	Pass
26677	Pass	26678	Pass	26679	Pass	26680	Pass
26681	Pass	26682	Pass	26683	Pass	26684	Pass
26685	Pass	26686	Pass	26687	Pass	26688	Pass
26689	Pass	26690	Pass	26691	Pass	26692	Pass
26693	Pass	26694	Pass	26695	Pass	26696	Pass
26697	Pass	26698	Pass	26699	Pass	26700	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory