



Warranty Certificate

Date: 01-10-2025**Manufacturer:** Kanex Fire Solutions Limited.**Customer Name:** V-Tech Fire**Warranty Start Date:** 01-10-2025**Warranty End Date:** 30-09-2026.

This is to certify that the below extinguishers are warranted for a period of **1** year from the date of supply against any of Manufacturing/Quality defects.

NOTE - IF TAMPER SEAL IS NOT INTACT, THE WARRANTY SHALL BE CONSIDERED VOID.

Sr.No.	Type & Capacity of Extinguishers	Quantity	Sr. Nos.
1	KFARQ-4-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg.	11	As Per Annexure - I
2	KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	6	As Per Annexure - I
3	KFCRQ-4.5-Kanex CO2 High Pressure Fire Extinguisher Cap. 4.5 Kg.	4	As Per Annexure - I
4	KFMSRQ-9-Kanex M Foam SP Fire Extinguisher Cap. 9 Ltr.	1	As Per Annexure - I
5	KFCRQ-2-Kanex CO2 High Pressure Fire Extinguisher Cap. 2 Kg.	12	As Per Annexure - I
6	KFWRQ-45-Kanex Water Trolley Mounted Fire Extinguisher Cap. 45 Ltr.	2	As Per Annexure - I

Also certify that, all the Fire extinguishers supplied against Invoice **No. 25-26/K/004372 Dated: 01-10-2025 P.O.No. VTECHF/PO-09/2025-26** are hydraulically tested 100% at 35 bar except CO2 and randomly tested for performance test. All the extinguishers confirms to IS 15683:2018 (Portable) or IS 16018:2012 (Mobile) requirements.

Note : If applicable CO2 Cylinders are PESO approved & HPT tested at 225 bar by Cylinder Manufacturer.

**Authorized Signatory**