

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/145/25	Model No.: MARQ-6-40%	Date: 18-08-2025
Type and Capacity of Extinguisher	: MARQ-6-40%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ40%6 145/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 14401 To 14500 And 14405A	
Month of Manufacturing	: Aug/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 14405A and removed from the Lot/Batch							
14401	Pass	14402	Pass	14403	Pass	14404	Pass
14405	Pass	14406	Pass	14407	Pass	14408	Pass
14409	Pass	14410	Pass	14411	Pass	14412	Pass
14413	Pass	14414	Pass	14415	Pass	14416	Pass
14417	Pass	14418	Pass	14419	Pass	14420	Pass
14421	Pass	14422	Pass	14423	Pass	14424	Pass
14425	Pass	14426	Pass	14427	Pass	14428	Pass
14429	Pass	14430	Pass	14431	Pass	14432	Pass
14433	Pass	14434	Pass	14435	Pass	14436	Pass
14437	Pass	14438	Pass	14439	Pass	14440	Pass
14441	Pass	14442	Pass	14443	Pass	14444	Pass
14445	Pass	14446	Pass	14447	Pass	14448	Pass
14449	Pass	14450	Pass	14451	Pass	14452	Pass
14453	Pass	14454	Pass	14455	Pass	14456	Pass
14457	Pass	14458	Pass	14459	Pass	14460	Pass
14461	Pass	14462	Pass	14463	Pass	14464	Pass
14465	Pass	14466	Pass	14467	Pass	14468	Pass
14469	Pass	14470	Pass	14471	Pass	14472	Pass
14473	Pass	14474	Pass	14475	Pass	14476	Pass
14477	Pass	14478	Pass	14479	Pass	14480	Pass
14481	Pass	14482	Pass	14483	Pass	14484	Pass
14485	Pass	14486	Pass	14487	Pass	14488	Pass
14489	Pass	14490	Pass	14491	Pass	14492	Pass
14493	Pass	14494	Pass	14495	Pass	14496	Pass
14497	Pass	14498	Pass	14499	Pass	14500	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory