

HELIUM LEAK DETECTION TEST

TC No.: HLD/A6/K/HQ/078/25	Model No.: KFKHQ-6	Date: 13-09-2025
Type and Capacity of Extinguisher	: KFKHQ-6-Kanex F Class Kitchen Fire Extinguisher Cap. 6 Ltr.	
Batch Number	: KFKHQ6 078/25	
Batch Quantity	: 10 Nos.	
Serial Numbers	: 00771 To 780	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
771	Pass	772	Pass	773	Pass	774	Pass
775	Pass	776	Pass	777	Pass	778	Pass
779	Pass	780	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers has been tested on Mass Spectrometer Helium Leak Detector, with test pressure of 1 mbar and desired leak rate of 1×10^{-6} mbar.l/sec and no any cylinders shows leakage beyond this limit.



Authorized Signatory